

State of GA, Healthcare Facility Regulation Division


STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: ALC000706	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED 02/06/2023
--	--	---	---

NAME OF PROVIDER OR SUPPLIER ARBOR AT BRIDGEMILL, THE	STREET ADDRESS, CITY, STATE, ZIP CODE 700 FREEDOM BLVD CANTON, GA 30114
---	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
L 000	Initial Comments.	L 000	Exhibit "A"	
L1132 SS=D	<p>111-8-63-.11(9)(a) Fire Safety.</p> <p>The assisted living community must comply with applicable fire and safety rules published by the Office of the Safety Fire Commissioner.</p> <p>This RULE is not met as evidenced by: >>>> Based on record review, the facility failed to comply with applicable fire and safety rules, specifically addressing fire safety rules and regulations.</p> <p>A review of the Fire Safety Inspection Report dated January 27, 2023 showed outstanding violations from the Fire Marshall indicating that the facility is not in compliance with applicable fire and safety rules and regulations. Instructions on this Fire Safety Inspection Report require that the facility submit an acceptable plan of correction within 30 days to the Fire Marshall's office.</p>	L1132	<p>1) Egress not to be blocked – corrected 1/30/23</p> <p>2) Open J Box – all pull boxes, junction boxes & conduit bodies shall be provided with covers – completed 2/24/23</p> <p>3) Riser Room to have sign – completed 2/3/23</p> <p>4) Extension Cords & flex cords not used as permanent wiring – corrected 1/27/23</p> <p>5) Fire Alarm inspection report available for examination – Inspection completed 4/19/23</p> <p>6) Sprinkler Inspection required –Sprinkler Inspection completed 4/19/23</p> <p>7) Sprinkler System has been repaired and is fully operational as of 1/30/23.</p> <p>8) External Leak that caused damage to Fire Panel completed 2/15/23.</p> <p>9) Fire Panel components replaced and repaired - work completed 2/28/23</p>	

State of GA Inspection Report
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

Brooke Figueras



Executive Director

(X6) DATE
4/19/2023